

Waste2GridS 826161

Publishable Summary Project Results and Exploitation Plan

Converting WASTE to offer flexible GRID balancing Services with highly-integrated, efficient solid-oxide plants


Duration: 2019.01-2020.12

Budget: 528750 €

Coordinator: Ligang Wang (ligang.wang@epfl.ch)
Jan Van herle (jan.vanherle@epfl.ch)

Officer: Antonio Aguilo-Rullan
antonio.aguilo-rullan@fch.europa.eu

A new potential service from biowastes



Biomass/biowaste can potentially participate grid balancing for high penetration of renewable energy sources (RES), given **enhanced efficiency, reduced cost and increased utilization rate**

One plant **capable of switching between electricity and methane production** can enable high annual utilization and cost reduction by sharing major components


Solid-oxide cell (SOC) technology

The most suitable syngas conversion technology for biomass utilization


RES power




SOEC mode




Chemicals



SOFC mode



Power




- High efficiency at a potentially low cost due to no use of noble metal
- High fuel flexibility with no poisoning impact of CO/CO₂: syngas as fuel for SOFC mode, syngas-to-methane via H₂ from SOEC
- Reversible operation with flexible switch between fuel cell mode (power generation) and electrolysis mode (power storage)

Waste2GridS concept



Triple-mode grid-balancing plant by integrating biomass gasification & SOC




❑ **Non-stop, highly-efficient, full-load** operation for high annual operation hours, i.e., theoretically 365 x 24h with no stand-by mode

❑ Potentially-large **investment reduction** due to key component sharing and syngas-to-methane **with no carbon capture**

Waste2GridS realization


The coordination of two stack blocks enables the realization of three modes



❑ **Constant operation** of biomass processing, syngas production/cleaning

❑ Mode switch by coordinating stack blocks, BoP and methane reactor

Economic evaluation considerations




Factors affecting economic feasibility of W2G plants:

- Grid-balancing service
- Plant design, performance & operation
- Chemical onsite storage and trade
- Biomass supply cost

Theoretical grid flexibility needs 2030

Flexibility-need prediction via historical data and energy development plans




❑ Capacity wise, three RES dominated zones has significant UP and DOWN regulation needs, reaching **several to even tens of GW level**

❑ Energy wise, three zones present **annual excess electricity of 5-7 TWh**, to be addressed by multiple flexibility means, e.g., cross-country transmission, traditional fossil plants and **new flexibility capacities**



Waste availability 2030

Waste availability predicted via biomass databases, GIS & EU directives



- Total energy of **theoretical** grid flexibility needs is at the same magnitude of the energy of local available waste and biomass
- Since actual W2G contribution will be much less than the theoretical value, local waste & biomass is sufficient to drive W2G for grid services

Multi-objective optimal plant design considering multiple degrees of freedom: technology combination, key component specifications and heat integration



$$\eta_{PowGen} = \frac{\text{Net power produced}}{\text{biom energy in}}$$

$$\eta_{PowSto} = \frac{\text{LHV energy of CH}_4}{\text{Biom energy in} + \text{net elec. in}}$$

$$\eta_{PowNeu} = \frac{\text{LHV energy of CH}_4}{\text{Biom energy in}}$$

A set of optimal designs with trade-off performances obtained

High efficiency enabled for all modes: PowGen & PowSto efficiencies much higher than state-of-the-art single-mode systems, PowNeu mode as an efficient productive alternative of non-productive stand-by

Plant CAPEX threshold/real



Plant CAPEX levelized to reference stack enabling one indicator for three modes

$$\text{Plant CAPEX threshold} = \frac{\text{Maximum possible profit of all plant installed}}{\text{number of reference stacks of all plants installed}}$$


$$\text{Plant CAPEX real} = \frac{\text{Evaluated plant CAPEX of all plant installed}}{\text{number of reference stacks of all plants installed}}$$

reference stack: a stack with 5120 cm² active area

- Plant CAPEX real < threshold, likely economically feasible
- Plant CAPEX real > threshold, likely economically infeasible

Economic feasibility identification

Plant CAPEX threshold and real evaluated for 40 case studies in DK and IT



Key economic assumptions

- Reference energy balancing price 40 €/MWh
- Reference payback time 5 years
- Stack lifetime: 5-year continuous operation
- Synthesis natural-gas price: 0.8 €/kg
- Annual cell production volume > 50,000 m²

❑ Economic feasibility enhanced by increased annual PowGen&PowSto hours. Feasible business cases when **annual PowGen&PowSto operation for over 3500 hours**.

❑ Economic feasibility mainly affected by grid-service gain and biomass supply cost. Plants below 100 MW_{th_biomass} are feasible, while 100–1000 MW_{th} plants become not feasible due to biomass supply.

Key conditions for economic feasibility







Given current market circumstances, W2G concept could be feasible if stack costs have significant cost reduction

Plant scales	100 MWth biomass feed ≈60 MWe PowGen power ≈160 MWe PowSto power
Payback time	5 years
Balancing price	40 €/MWh
Stack lifetime	5 years
SNG selling price	0.8 €/kg
PowGen&PowSto hours	> 3500
Stack costs	< 1600 €/kWe-SOFC

Scaling up strategy

The method of plant scale-up from kW-level to MW-level plant?



Key conclusions



- ❑ Large grid flexibility needs in DK and IT-SUD in 2030
- ❑ **Local biomass** sufficient to contribute significantly to grid balancing
- ❑ W2G concept enables **highly-efficient grid-balancing service**
- ❑ Given current grid-balancing prices, methane price and stack lifetime, economical feasible case studies exist with the conditions:
 - ❑ Single plant scale: biomass feed of up to a few hundreds of MW_{th} , PowGen power up to 100 MWe, PowSto power up to a few hundreds of MWe
 - ❑ **PowGen&PowSto hours: > 3500 hours**
 - ❑ **Stack costs: < 1600 €/kWe-SOFC**

Exploitation plan



Project results	Partner	Exploitation activities
1) Plant conceptual design (D2.1) 2) Technical bottleneck (D3.2) 3) Economic feasibility and prerequisites (D3.3)	EPFL SP	DG Ener, FCHJU and biomass community: Promote stage-wise component and system development towards modular system design approach enabling smooth mode switch for flexible plant operation and sufficient characterization of system dynamic responses
1) Qualification requirement of solid-oxide technology for grid-balancing service (D1.1/D3.2) 2) Prerequisites of economic-feasible case studies (D2.2/D3.3)	DTU ENEA	Major EU TSOs and EU electrical grid community: <ul style="list-style-type: none"> - Promote pioneer evaluation of technical feasibility of using separate SOFC and SOEC systems for grid-balancing service - Determine the types of grid-balancing services and the priority of using biomass for grid-balancing service.
1) New way of biomass or biowastes utilization (D2.1/D3.2)	ENEA	Biomass community and policy maker: <ul style="list-style-type: none"> - whether W2G concept could be a better option of biomass utilization among various ways of using them. - Potential subsidy for W2G concept.
1) Scale-up strategy (D3.1) 2) Economic feasibility (D3.3)	SP	Solid-oxide technology community: <ul style="list-style-type: none"> - Promote the awareness of the need of several tens of MW SOFC system as an important scenario of technology development - Increase the interest in technology scale-up for MW level above, and to enhance more robust stacks.

Recommendation on FCHJU program



Two-phase funding plan

2022

2027

2030



Demonstration:

- (1) 25kWe biogas-fed RSOC plant,
- (2) 75-100kWe biomass gasification-SOEC for producing SNG



Focus:

- (1) Comp. development, e.g., low-cost gas cleaning & robust large stack
- (2) System demo. and modular operation
- (3) Characterization of the capability of stack and systems for grid service
- (4) Stack & system scaleup

Demonstration:

- (1) MW-level demo. of biomass-SOC integrated plants or W2G plant
- (2) Characterization of the W2G plants for grid services



Acknowledgement:

This project has received funding from the Fuel Cells and Hydrogen Joint Undertaking under grant agreement No 826161.

This Joint Undertaking receives support from the European Union's Horizon 2020 research and innovation programme, Hydrogen Europe and Hydrogen Europe research.

